



Environmental Self Declaration – Volatile Organic Compounds.  
Made in Accordance with **ClearChem** Standard BKA-CC-01

# Self-Declared Certificate of Product Conformity VOC Emissions



**FINISH RIGHT**

## Company Information

Company Name:	Rodda Paint Co.
Contact Information:	products@roddapaint.com, 800-452-2315
Website:	www.roddapaint.com

## Product Information

Product Name:	EcoLogic Rustex Primer
Product Number:	70323
Product Line:	EcoLogic
Product Category:	Paints & Coatings

## Exclusions

Exclusions:	None
-------------	------

## VOC Content

Regulatory VOC Content g/L:	<100 g/L
Regulation:	SCAQMD Rule 1113
Category:	Primers, Sealers, and Undercoaters
VOC Content test or determination method:	Calculated from formulation
Exempt compounds >1% weight by mass of product:	None
Does product contain methylene chloride or perchloroethylene?:	No

## VOC Emissions

Test Standard:	<b>CDPH Standard Method V1.1</b>
Acceptance Criteria:	<b>CDPH Standard Method V1.1</b>
Use scenario(s) Product type:	<b>Wall Paint &amp; Wall Coverings</b>
Building Type:	<b>Classroom+Office</b>
Product coverage g/m <sup>2</sup> :	<b>140</b>
TVOC concentration at 14-days:	<b>Less or equal to 0.5 mg/m3</b>
Direct or extended claim:	<b>Extended</b>

## Compliance Testing

ISO/IEC 17025 accredited third-party laboratory:	<b>Berkeley Analytical, IAS TL-383</b>
Test start date:	<b>10/14/2016</b>
Laboratory certificate number:	<b>161103-06</b>

## Extended Claim for Co-product

Name of compliance tested product:	<b>ECOLOGIC Interior Exterior 100% Acrylic Semi Gloss Enamel</b>
Number:	<b>70623</b>
Was listed product screening-level tested for VOC emissions?:	<b>Yes</b>
Basis for extension of claim from compliant product to co-product:	<b>Representative samples submitted for screening were provided from production packaged goods. Products were tested and assured to meet all QC performance requirements of the product line.</b>
Brief description of procedures used to ensure product is represented by compliance test results:	<b>Product manufactured using similar formulation, processing and VOC profile.</b>

## Quality Control

Company maintains internal quality control program to ensure manufactured units are produced consistently and meet the requirements and acceptance criteria of listed standard(s):	<b>Yes</b>
Tested product sample was selected from typical production and is representative of commercial product. Where there are expected variations, sample was selected from production lot or group expected to give worst-case results:	<b>Yes</b>
If claim is for product other than product that was sampled and compliance tested, company maintains record of procedures used for extending claim in form of test results, calculations, formulations, or other information:	<b>Yes</b>

## Self-Declaration Signature

I affirm that I am authorized to make claims established in this declaration:	Yes
I certify that the information in this declaration is true and correct:	Yes
Date:	04/02/2018
Name of company representative:	Jim Armstrong
Title:	Lab Manager
Signature:	Jim Armstrong

This ClearChem template is a standardized reporting form used by companies to make self-declared claims about the environmental performance of their products. Only companies that have entered into a binding Implementation Agreement with Berkeley Analytical may use this form.

**DISCLAIMER: THIS SELF-DECLARATION OF CONFORMITY (“SELF-DECLARATION”) IS A STATEMENT MADE BY THE COMPANY AND ALL DECLERATIONS MADE HEREIN ARE THE SOLE RESPONSIBILITY OF THE COMPANY. BERKELEY ANALYTICAL ASSOCIATES, LLC (“BKA”) SHALL HAVE NO LIABILITY FOR ANY STATEMENTS MADE IN THIS SELF-DECLARATION. ANY TEST RESULTS FURNISHED BY BKA TO COMPANY ARE LIMITED TO THE SAMPLE OF THE PRODUCT IDENTIFIED IN THIS DECLARATION, AND BKA IS NOT RESPONSIBLE FOR ANY COMPANY CLAIMS REGARDING A PRODUCT OR PRODUCTS ENTERED INTO COMMERCE THAT MAY BE BASED ON BKA TESTING. BKA’S TESTING DOES NOT CONSTITUTE AN ENDOREMENT OF ANY PRODUCT OF THE COMPANY. BKA HAS NO LIABILITY FOR THE PERFORMANCE, QUALITY, OR CONFORMANCE WITH THE REFERENCE STANDARD(S) OF ANY PRODUCT DECLARED TO BE CONFORMING TO SUCH STANDARD(S). BKA MAKES NO REPRESENTATIONS, WARRANTIES, OR CERTIFICATIONS REGARDING THE USABILITY, PUBLIC HEALTH, AND MEDICAL, TOXICOLOGICAL, OR ENVIRONMENTAL IMPACT OF THE COMPANY’S PRODUCT OR SUCH PRODUCT’S COMPLIANCE WITH ANY APPLICABLE STANDARDS, SPECIFICATIONS, REQUIREMENTS, LAWS, OR REGULATIONS. BKA PROVIDES THE SELF-DECLARATION TEMPLATE “AS IS” WITHOUT WARRANTY OF ANY KIND, EITHER EXPRESSED OR IMPLIED, INCLUDING BUT NOT LIMITED TO, THE IMPLIED WARRANTIES OF MERCHANTABILITY OR FITNESS FOR ANY PURPOSE. BKA SHALL NOT INCUR ANY LIABILITY FOR ANY DAMAGES, INCLUDING, BUT NOT LIMITED TO, DIRECT, INDIRECT, SPECIAL, OR CONSEQUENTIAL DAMAGES ARISING OUT OF, RESULTING FROM, OR IN ANY WAY CONNECTED TO THE USE OF ANY PRODUCT, WHETHER OR NOT BASED UPON WARRANTY, CONTRACT, TORT, OR OTHERWISE; WHETHER OR NOT INJURY WAS SUSTAINED BY PERSONS OR PROPERTY OR OTHERWISE; AND WHETHER OR NOT LOSS WAS SUSTAINED FROM, OR AROSE OUT OF, THE RESULTS OF THE COMPANY’S PRODUCT, OR ANY SERVICES THAT MAY BE PROVIDED BY BKA. ALL INQUIRIES CONCERNING THIS SELF-DECLARATION SHOULD BE DIRECTED TO THE COMPANY.**




# COMPLIANCE TESTED by berkeley analytical

## VOC Emission Test Certificate

**Product Name:** ECOLOGIC Interior/exterior 100% Acrylic Latex Semi Gloss / 70623

Product Sample Information	
Manufacturer:	Rodda Paint Company
Manf. Website:	www.rodmapaint.com
CSI Category & No.:	Interior Painting (09 91 23)
Date Produced:	8/2/2016

Certificate Information	
Certificate No:	161103-06
Certified By:	 Raja S. Tannous, Laboratory Director
Date:	November 3, 2016

**Reference Standard:** California Department of Public Health CDPH/EHLB/Standard Method Version 1.1, 2010 (Emission testing method for CA Specification 01350)

**Acceptance Criteria and Results Demonstrating Compliance of Product Sample to Referenced Standard:**

Exposure Scenario <sup>1</sup>	Individual VOCs of Concern <sup>2</sup>		Formaldehyde <sup>3</sup>		TVOC <sup>4</sup>
	Criterion	Compliant?	Criterion	Compliant?	Range
School Classroom	≤½ Chronic REL	YES	≤9.0 µg/m <sup>3</sup>	YES	≤ 0.5 mg/m <sup>3</sup>
Private Office	≤½ Chronic REL	YES	≤9.0 µg/m <sup>3</sup>	YES	≤ 0.5 mg/m <sup>3</sup>

**Product Coverage<sup>5</sup>:** 140 g/m<sup>2</sup>

1. Exposure scenarios & product quantities for classroom & office are defined in Tables 4-2 – 4-5 (CDPH Std. Mtd. V1.1-2010)
2. Maximum allowable concentrations of individual target VOCs are specified in Table 4-1 (*ibid.*)
3. Maximum allowable formaldehyde concentration is ≤9 µg/m<sup>3</sup>, effective Jan 1, 2012; previous limit was ≤16.5 µg/m<sup>3</sup> (*ibid.*)
4. Informative only; predicted TVOC Range in three categories, i.e., ≤0.5 mg/m<sup>3</sup>, >0.5 – 4.9 mg/m<sup>3</sup>, and ≥5.0 mg/m<sup>3</sup>
5. Informative and applicable only to tests of wet-applied products; grams of sample applied per square meter of substrate

**Standards & Codes Recognizing CDPH Standard Method V1.1 (partial list)**

- ANSI/ASHRAE/USGBC/IES Standard 189.1-2011
- USGBC LEED for Schools, 2009
- Collaborative for High Performance Schools (CHPS), National Core Criteria, 2013
- USGBC LEED Version 4, BD&C, ID&C, 2013
- ANSI/GBI 01-2010, Green Building Assessment Protocol

**Narrative:** Rodda Paint Company selected a sample representative of its ECOLOGIC Interior/exterior 100% Acrylic Latex Semi Gloss product and submitted it on 10/10/2016 for testing. Berkeley Analytical measured and evaluated the emissions of VOCs from this sample following CDPH/EHLB/Standard Method V1.1-2010. The results of the test are presented in Berkeley Analytical report, 881-001-09A-Nov0316.

**Berkeley Analytical** is an independent, third-party laboratory specializing in the analysis of organic chemicals emitted by and contained in building products, finishes, furniture, and consumer products. We are an ISO/IEC 17025 accredited laboratory (IAS, [TL-383](#)); all standards used in performing this test are in Berkeley Analytical's scope of accreditation.

**DISCLAIMER:** THIS CERTIFICATE OF COMPLIANCE AFFIRMS THAT: 1) A SAMPLE OF THE LISTED PRODUCT WAS TESTED ACCORDING TO THE REFERENCED STANDARD; 2) THE MEASURED VOC EMISSIONS FROM THE SAMPLE WERE EVALUATED FOR THE DEFINED EXPOSURE SCENARIO(S); AND 3) THE RESULTS MEET THE ACCEPTANCE CRITERIA OF THE REFERENCED STANDARD(S). BERKELEY ANALYTICAL IS NOT RESPONSIBLE FOR ANY CLAIMS REGARDING A PRODUCT OR PRODUCTS ENTERED INTO COMMERCE THAT MAY BE BASED ON THIS TEST. BERKELEY ANALYTICAL PROVIDES THIS CERTIFICATE OF COMPLIANCE "AS IS" WITHOUT WARRANTY OF ANY KIND,

©2012 Berkeley Analytical, 815 Harbour Way South, Suite 6, Richmond, CA 94804 / 510-236-2325 / [www.berkeleyanalytical.com](http://www.berkeleyanalytical.com)  
FC17B.1